

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 2



KEMPSEY SHIRE COUNCIL
BLAKE GIDDY
P.O. BOX 3078
WEST KEMPSEY NSW 2440

BATCHNUMBER: 23/2808
No. of SAMPLES: 5
DATE COLLECTED: 20/12/23
DATE RECEIVED: 20/12/23
TIME RECEIVED: 17:00
DATE TESTING COMMENCED:
20/12/23

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
23/2808/1	South Kempsey TP
23/2808/2	Crescent Head CW
23/2808/3	West Kempsey TP
23/2808/4	Hat Head C. Well
23/2808/5	South Kempsey STP Head Wall Day Pond

ANALYSIS	UNITS	23/2808/1	23/2808/2	23/2808/3	23/2808/4	METHOD NO
pH	pH unit	6.8	7.2	8.7	7.1	APHA 4500-H+ B
Conductivity	µS/cm	-	1,270	-	909	APHA 2510 B
Total Dissolved Solids	mg/L	-	-	-	582	EL7B
Turbidity	NTU	-	1.9	-	0.50	APHA 2130 B
Transmittance#	%	-	-	-	-	EL**32
Alkalinity	mg CaCO ₃ /L	-	-	-	58	APHA 2320 B
Total Suspended Solids	mg/L	7	7	23	<2	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L					APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-	-		-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L					APHA 4500-NH3 H
Total Nitrogen	mg/L					APHA 4500-P J
Total Phosphorus	mg/L					APHA 4500-P J
Potassium	mg/L	-	-	-		EL9A
Chloride	mg/L	-	-	-		EL10
Oil & Grease	mg/L					EL23A



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	23/2808/1	23/2808/2	23/2808/3	23/2808/4	METHODNO
Chlorophyll-a	µg/L	-	-		-	APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	14,400	<2	90	0	ELM 3

ANALYSIS	UNITS	23/2808/5				METHODNO
pH	pH unit	-				APHA 4500-H+ B
Conductivity	µS/cm	-				APHA 2510 B
Total Dissolved Solids	mg/L	-				EL7B
Turbidity	NTU	-				APHA 2130 B
Transmittance#	%	-				EL**32
Alkalinity	mg CaCO ₃ /L	-				APHA 2320 B
Total Suspended Solids	mg/L	-				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-				APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-				APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-				APHA 4500-NH3 H
Total Nitrogen	mg/L	-				APHA 4500-P J
Total Phosphorus	mg/L	-				APHA 4500-P J
Potassium	mg/L	-				EL9A
Chloride	mg/L	-				EL10
Oil & Grease	mg/L	-				EL23A
Chlorophyll-a	µg/L	-				APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	300				ELM 3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2022, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are presumptive.

Measurement Uncertainty is available upon request.

Report Date: 22/12/23



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.