

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 2



KEMPSEY SHIRE COUNCIL
BLAKE GIDDY
P.O. BOX 3078
WEST KEMPSEY NSW 2440

BATCHNUMBER: 25/0011
No. of SAMPLES: 5
DATE COLLECTED: 02/01/25
DATE RECEIVED: 02/01/25
TIME RECEIVED: 13:05
DATE TESTING COMMENCED:
02/01/25

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/0011/1	South Kempsey TP
25/0011/2	Crescent Head CW
25/0011/3	West Kempsey TP
25/0011/4	Hat Head C. Well
25/0011/5	South Kempsey STP Head Wall Day Pond

ANALYSIS	UNITS	25/0011/1	25/0011/2	25/0011/3	25/0011/4	METHOD NO
pH	pH unit	7.0	7.5	8.4	6.9	APHA 4500-H+ B
Conductivity	µS/cm	-	917	-	1,030	APHA 2510 B
Total Dissolved Solids	mg/L	-	-	-	659	EL7B
Turbidity	NTU	-	0.75	-	0.55	APHA 2130 B
Transmittance#	%	-	-	-	-	EL**32
Alkalinity	mg CaCO ₃ /L	-	-	-	33	APHA 2320 B
Total Suspended Solids	mg/L	3	<2	20	<2	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	4	<2	6	<2	APHA 5210 B
Nitrate Nitrogen	mg/L	-	1.38	0.04	13.4	APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-	-	<0.02	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	1.63	0.11	0.07	0.53	APHA 4500-NH3 H
Total Nitrogen	mg/L	2.73	2.36	1.86	14.0	APHA 4500-P J
Total Phosphorus	mg/L	6.63	0.09	0.21	0.03	APHA 4500-P J
Potassium	mg/L	-	-	-	28	EL9A
Chloride	mg/L	-	-	-	154	EL10
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0011/1	25/0011/2	25/0011/3	25/0011/4	METHODNO
Chlorophyll-a	µg/L	-	-	48	-	APHA 10200H
Thermotolerant Coliforms	cfu/100mL	1,500	<2	20	10	ELM3

ANALYSIS	UNITS	25/0011/5				METHODNO
pH	pH unit	-				APHA 4500-H+ B
Conductivity	µS/cm	-				APHA 2510 B
Total Dissolved Solids	mg/L	-				EL7B
Turbidity	NTU	-				APHA 2130 B
Transmittance#	%	-				EL**32
Alkalinity	mg CaCO ₃ /L	-				APHA 2320 B
Total Suspended Solids	mg/L	-				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-				APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-				APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-				APHA 4500-NH3 H
Total Nitrogen	mg/L	-				APHA 4500-P J
Total Phosphorus	mg/L	-				APHA 4500-P J
Potassium	mg/L	-				EL9A
Chloride	mg/L	-				EL10
Oil & Grease	mg/L	-				EL23A
Chlorophyll-a	µg/L	-				APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	1,800				ELM3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

Report Date: 13/01/25



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Number: 12359

Approved:

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.