

# COFFS HARBOUR LABORATORY

## Environmental Analysis

Page 1 of 6



KEMPSEY SHIRE COUNCIL  
BLAKE GIDDY  
P.O. BOX 3078  
WEST KEMPSEY NSW 2440

BATCHNUMBER: 25/0131  
No. of SAMPLES: 12  
DATE COLLECTED: 15/01/25  
DATE RECEIVED: 15/01/25  
TIME RECEIVED: 16:10  
DATE TESTING COMMENCED:  
15/01/25

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/0131/1	South Kempsey TP
25/0131/2	Crescent Head CW
25/0131/3	Gladstone TP
25/0131/4	Frederickton TP
25/0131/5	South West Rocks CW
25/0131/6	West Kempsey TP
25/0131/7	Hat Head C Well
25/0131/8	South Kempsey STP Head Wall Day Pond
25/0131/9	Upstream Gladstone TP
25/0131/10	Downstream Gladstone TP
25/0131/11	Upstream Frederickton TP
25/0131/12	Downstream Frederickton TP

ANALYSIS	UNITS	25/0131/1	25/0131/2	25/0131/3	25/0131/4	METHOD NO
pH	pH unit	7.0	7.0	8.7	8.2	APHA 4500-H+ B
Conductivity	$\mu\text{S}/\text{cm}$	-	882	-	-	APHA 2510 B
Turbidity	NTU	-	0.95	-	-	APHA 2130 B
Transmittance	%	-	-	43.4	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	-	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	-	-	-	-	APHA 2320 B
Total Suspended Solids	mg/L	2	3	32	39	APHA 2540 D
Biochem Oxygen Demand (BOD <sub>5</sub> )	mg/L	4	<2	9	20	APHA 5210 B



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0131/1	25/0131/2	25/0131/3	25/0131/4	METHODNO
Nitrate Nitrogen	mg/L	-	3.80	-	-	APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-	-	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	0.52	0.12	0.02	15.1	APHA 4500-NH3 H
Total Nitrogen	mg/L	1.82	5.15	2.01	20.4	APHA 4500-P J
Total Phosphorus	mg/L	6.60	0.18	6.25	7.24	APHA 4500-P J
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A
Chlorophyll-a	µg/L	-	-	54	106	APHA 10200 H
Potassium	mg/L	-	-	-	-	EL9A
Chloride	mg/L	-	-	-	-	EL10
Arsenic	mg/L	-	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	3,250	<2	3,100	2,040	ELM 3

ANALYSIS	UNITS	25/0131/5	25/0131/6	25/0131/7	25/0131/8	METHODNO
pH	pH unit	6.8	8.9	7.2	-	APHA 4500-H+ B
Conductivity	µS/cm	594	-	956	-	APHA 2510 B
Turbidity	NTU	1.7	-	0.40	-	APHA 2130 B
Transmittance	%	-	-	-	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	612	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	21	-	65	-	APHA 2320 B
Total Suspended Solids	mg/L	<2	50	<2	-	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	<2	10	<2	-	APHA 5210 B
Nitrate Nitrogen	mg/L	-	<0.02	0.94	-	APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-	<0.02	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	0.11	0.02	<0.02	-	APHA 4500-NH3 H
Total Nitrogen	mg/L	8.90	2.77	1.65	-	APHA 4500-P J
Total Phosphorus	mg/L	0.33	0.33	0.04	-	APHA 4500-P J
Oil & Grease	mg/L	<2	<2	<2	-	EL23A
Chlorophyll-a	µg/L	-	68	-	-	APHA 10200 H
Potassium	mg/L	19	-	22	-	EL9A
Chloride	mg/L	94	-	139	-	EL10
Arsenic	mg/L	<0.012	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	270	<10	0	1,650	ELM 3



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0131/9	25/0131/10	25/0131/11	25/0131/12	METHODNO
pH	pH unit	-	-	-	-	APHA 4500-H+ B
Conductivity	µS/cm	-	-	-	-	APHA 2510 B
Turbidity	NTU	-	-	-	-	APHA 2130 B
Transmittance	%	-	-	-	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	-	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	-	-	-	-	APHA 2320 B
Total Suspended Solids	mg/L	-	-	-	-	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-	-	-	-	APHA 5210 B
Nitrate Nitrogen	mg/L	-	-	-	-	APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-	-	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-	-	-	-	APHA 4500-NH3 H
Total Nitrogen	mg/L	-	-	-	-	APHA 4500-P J
Total Phosphorus	mg/L	-	-	-	-	APHA 4500-P J
Oil & Grease	mg/L	-	-	-	-	EL23A
Chlorophyll-a	µg/L	-	-	-	-	APHA 10200 H
Potassium	mg/L	-	-	-	-	EL9A
Chloride	mg/L	-	-	-	-	EL10
Arsenic	mg/L	-	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	330	130	70	15	ELM 3

ANALYSIS	UNITS	25/0131/1	25/0131/2	25/0131/3	25/0131/4	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
PFPeA (2706-90-3)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFHxA (307-24-4)	ug/L	0.015	<0.01	<0.01	0.014	NR70
PFHpA (375-85-9)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFOA (335-67-1)	ug/L	<0.01	<0.01	<0.01	0.063	NR70
PFNA (375-95-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDA (335-76-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFUdA (2058-94-8)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDoA (307-55-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFTTrDA (72629-94-8)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFTeDA (376-06-7)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFHxDA (67905-19-5)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFODO (16517-11-6)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
FOUEA (70887-84-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDS (335-77-3)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFPeS (2706-91-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFHxS (355-46-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFHpS (375-92-8)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFOS (1763-23-1)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFNS (68259-12-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFBS (375-73-5)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0131/1	25/0131/2	25/0131/3	25/0131/4	METHODNO
PFOSA (754-91-6)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-MeFOSA (31506-32-8)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
N-EtFOSA (4151-50-2)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
N-MeFOSAA (2355-31-9)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-EtFOSAA (2991-50-6)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-MeFOSE (24448-09-7)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
N-EtFOSE (1691-99-2)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
4:2FTS (757124-72-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
6:2FTS (27619-97-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
8:2FTS (39108-34-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
10:2FTS (120226-60-0)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
8:2diPAP (678-41-1)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70

ANALYSIS	UNITS	25/0131/5	25/0131/6	25/0131/7	25/0131/8	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	<0.05	<0.05	<0.05	-	NR70
PFPeA (2706-90-3)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFHxA (307-24-4)	ug/L	0.013	<0.01	<0.01	-	NR70
PFHpA (375-85-9)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOA (335-67-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFNA (375-95-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDA (335-76-2)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFUdA (2058-94-8)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDoA (307-55-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFTTrDA (72629-94-8)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFTeDA (376-06-7)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFHxDA (67905-19-5)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFODO (16517-11-6)	ug/L	<0.05	<0.05	<0.05	-	NR70
FOUEA (70887-84-2)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDS (335-77-3)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFPeS (2706-91-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFHxS (355-46-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFHpS (375-92-8)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOS (1763-23-1)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFNS (68259-12-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFBS (375-73-5)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOSA (754-91-6)	ug/L	<0.01	<0.01	<0.01	-	NR70
N-MeFOSA (31506-32-8)	ug/L	<0.02	<0.02	<0.02	-	NR70
N-EtFOSA (4151-50-2)	ug/L	<0.02	<0.02	<0.02	-	NR70
N-MeFOSAA (2355-31-9)	ug/L	<0.01	<0.01	<0.01	-	NR70
N-EtFOSAA (2991-50-6)	ug/L	<0.01	<0.01	<0.01	-	NR70
N-MeFOSE (24448-09-7)	ug/L	<0.05	<0.05	<0.05	-	NR70
N-EtFOSE (1691-99-2)	ug/L	<0.05	<0.05	<0.05	-	NR70
4:2FTS (757124-72-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
6:2FTS (27619-97-2)	ug/L	<0.01	<0.01	<0.01	-	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0131/5	25/0131/6	25/0131/7	25/0131/8	METHODNO
8:2FTS (39108-34-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
10:2FTS (120226-60-0)	ug/L	<0.01	<0.01	<0.01	-	NR70
8:2diPAP (678-41-1)	ug/L	<0.02	<0.02	<0.02	-	NR70

ANALYSIS	UNITS	25/0131/9	25/0131/10	25/0131/11	25/0131/12	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	-	-	-	-	NR70
PFPeA (2706-90-3)	ug/L	-	-	-	-	NR70
PFHxA (307-24-4)	ug/L	-	-	-	-	NR70
PFHpA (375-85-9)	ug/L	-	-	-	-	NR70
PFOA (335-67-1)	ug/L	-	-	-	-	NR70
PFNA (375-95-1)	ug/L	-	-	-	-	NR70
PFDA (335-76-2)	ug/L	-	-	-	-	NR70
PFUdA (2058-94-8)	ug/L	-	-	-	-	NR70
PFDoA (307-55-1)	ug/L	-	-	-	-	NR70
PFTrDA (72629-94-8)	ug/L	-	-	-	-	NR70
PFTeDA (376-06-7)	ug/L	-	-	-	-	NR70
PFHxDA (67905-19-5)	ug/L	-	-	-	-	NR70
PFODO (16517-11-6)	ug/L	-	-	-	-	NR70
FOUEA (70887-84-2)	ug/L	-	-	-	-	NR70
PFDS (335-77-3)	ug/L	-	-	-	-	NR70
PFPeS (2706-91-4)	ug/L	-	-	-	-	NR70
PFHxS (355-46-4)	ug/L	-	-	-	-	NR70
PFHpS (375-92-8)	ug/L	-	-	-	-	NR70
PFOS (1763-23-1)	ug/L	-	-	-	-	NR70
PFNS (68259-12-1)	ug/L	-	-	-	-	NR70
PFBS (375-73-5)	ug/L	-	-	-	-	NR70
PFOSA (754-91-6)	ug/L	-	-	-	-	NR70
N-MeFOSA (31506-32-8)	ug/L	-	-	-	-	NR70
N-EtFOSA (4151-50-2)	ug/L	-	-	-	-	NR70
N-MeFOSAA (2355-31-9)	ug/L	-	-	-	-	NR70
N-EtFOSAA (2991-50-6)	ug/L	-	-	-	-	NR70
N-MeFOSE (24448-09-7)	ug/L	-	-	-	-	NR70
N-EtFOSE (1691-99-2)	ug/L	-	-	-	-	NR70
4:2FTS (757124-72-4)	ug/L	-	-	-	-	NR70
6:2FTS (27619-97-2)	ug/L	-	-	-	-	NR70
8:2FTS (39108-34-4)	ug/L	-	-	-	-	NR70
10:2FTS (120226-60-0)	ug/L	-	-	-	-	NR70
8:2diPAP (678-41-1)	ug/L	-	-	-	-	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

**Comments**

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

\*Analysis conducted by a subcontracted laboratory (NATA Accreditation Number 198) RN 1453997.

Report Date: 30/01/25



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

Approved:

A handwritten signature in black ink that reads "Shane Ewart".

Shane Ewart  
Technical Supervisor  
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.