

# COFFS HARBOUR LABORATORY

## Environmental Analysis

Page 1 of 2



KEMPSEY SHIRE COUNCIL  
BLAKE GIDDY  
P.O. BOX 3078  
WEST KEMPSEY NSW 2440

BATCHNUMBER: 25/0493  
No. of SAMPLES: 5  
DATE COLLECTED: 26/02/25  
DATE RECEIVED: 26/02/25  
TIME RECEIVED: 15:40  
DATE TESTING COMMENCED:  
26/02/25

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
25/0493/1	South Kempsey TP
25/0493/2	Crescent Head CW
25/0493/3	West Kempsey TP
25/0493/4	Hat Head C. Well
25/0493/5	South Kempsey STP Head Wall Day Pond

ANALYSIS	UNITS	25/0493/1	25/0493/2	25/0493/3	25/0493/4	METHOD NO
pH	pH unit	6.9	7.2	8.5	7.5	APHA 4500-H+ B
Conductivity	µS/cm	-	911	-	988	APHA 2510 B
Total Dissolved Solids	mg/L	-	-	-	632	EL7B
Turbidity	NTU	-	5.3	-	0.40	APHA 2130 B
Transmittance#	%	-	-	-	-	EL**32
Alkalinity	mg CaCO <sub>3</sub> /L	-	-	-	120	APHA 2320 B
Total Suspended Solids	mg/L	2	10	9	<2	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	5	6	10	<2	APHA 5210 B
Nitrate Nitrogen	mg/L	-	0.16	1.40	0.04	APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-	-	1.14	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	3.16	3.00	0.52	0.02	APHA 4500-NH3 H
Total Nitrogen	mg/L	3.80	4.89	4.37	0.68	APHA 4500-P J
Total Phosphorus	mg/L	3.23	0.56	0.19	0.07	APHA 4500-P J
Potassium	mg/L	-	-	-	20	EL9A
Chloride	mg/L	-	-	-	136	EL10
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	25/0493/1	25/0493/2	25/0493/3	25/0493/4	METHODNO
Chlorophyll-a	µg/L	-	-	27	-	APHA 10200H
Thermotolerant Coliforms	cfu/100mL	2,100	500	<10	2	ELM3

ANALYSIS	UNITS	25/0493/5				METHODNO
pH	pH unit	-				APHA 4500-H+ B
Conductivity	µS/cm	-				APHA 2510 B
Total Dissolved Solids	mg/L	-				EL7B
Turbidity	NTU	-				APHA 2130 B
Transmittance#	%	-				EL**32
Alkalinity	mg CaCO <sub>3</sub> /L	-				APHA 2320 B
Total Suspended Solids	mg/L	-				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-				APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-				APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-				APHA 4500-NH3 H
Total Nitrogen	mg/L	-				APHA 4500-P J
Total Phosphorus	mg/L	-				APHA 4500-P J
Potassium	mg/L	-				EL9A
Chloride	mg/L	-				EL10
Oil & Grease	mg/L	-				EL23A
Chlorophyll-a	µg/L	-				APHA 10200 H
Thermotolerant Coliforms	cfu/100mL	8,300				ELM3

### Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2023, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Measurement Uncertainty is available upon request.

Report Date: 5/03/25



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

Approved:

Shane Ewart  
Technical Supervisor  
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.