

COFFS HARBOUR LABORATORY

Environmental Analysis

Page 1 of 2



KEMPSEY SHIRE COUNCIL
PETER BRADFORD
P.O. BOX 3078
WEST KEMPSEY NSW 2440

BATCHNUMBER: 22/0638
No. of SAMPLES: 5
DATE COLLECTED: 30/03/22
DATE RECEIVED: 30/03/22
TIME RECEIVED: 11:30
DATE TESTING COMMENCED:
30/03/22

REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
22/0638/1	South Kempsey TP
22/0638/2	Crescent Head CW
22/0638/3	North St Final TP
22/0638/4	Hat Head C. Well
22/0638/5	South Kempsey STP Head Wall Day Pond

ANALYSIS	UNITS	22/0638/1	22/0638/2	22/0638/3	22/0638/4	METHOD NO
pH	pH unit	6.7	6.7	6.9	7.5	APHA 4500-H+B
Conductivity	µS/cm	-	363	-	-	APHA 2510 B
Total Dissolved Solids	mg/L	128	232	227	521	EL7B
Turbidity	NTU	-	27	-	7.0	APHA 2130 B
Alkalinity	mg CaCO ₃ /L	-	-	-	126	APHA 2320 B
Total Suspended Solids	mg/L	14	18	13	6	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	3	3	4	<2	APHA 5210 B
Nitrate Nitrogen	mg/L	1.92	2.69	2.66	0.73	APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	0.10	<0.02	0.38	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	0.80	0.74	3.01	0.93	APHA 4500-NH3 H
Total Nitrogen	mg/L	2.96	3.64	6.62	2.22	APHA 4500-P J
Total Phosphorus	mg/L	0.67	0.34	0.36	0.19	APHA 4500-P J
Potassium	mg/L	-	-	-	10	EL9A
Chloride	mg/L	-	-	-	55	EL10
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A
Chlorophyll-a	µg/L	-	-	30	-	APHA 10200 H



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	22/0638/1	22/0638/2	22/0638/3	22/0638/4	METHODNO
Faecal Coliforms	cfu/100mL	6,000	15	1,260	0	ELM3

ANALYSIS	UNITS	22/0638/5				METHODNO
pH	pH unit	-				APHA 4500-H+ B
Conductivity	µS/cm	-				APHA 2510 B
Total Dissolved Solids	mg/L	-				EL7B
Turbidity	NTU	-				APHA 2130 B
Alkalinity	mg CaCO ₃ /L	-				APHA 2320 B
Total Suspended Solids	mg/L	-				APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-				APHA 5210 B
Nitrate Nitrogen	mg/L	-				APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-				APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-				APHA 4500-NH3 H
Total Nitrogen	mg/L	-				APHA 4500-P J
Total Phosphorus	mg/L	-				APHA 4500-P J
Potassium	mg/L	-				EL9A
Chloride	mg/L	-				EL10
Oil & Grease	mg/L	-				EL23A
Chlorophyll-a	µg/L	-				APHA 10200 H
Faecal Coliforms	cfu/100mL	8,400				ELM3

Comments

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 23rd Edition, 2017, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are membrane presumptive.

Measurement Uncertainty is available upon request.

Report Date: 5/04/22



Accredited for compliance with ISO/IEC 17025 - Testing
[Accreditation Numbers: 12359 (Chemical) & 14565 (Microbiological)]

Approved:

Shane Ewart
Technical Supervisor
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australia