

# COFFS HARBOUR LABORATORY

## Environmental Analysis

Page 1 of 7



KEMPSEY SHIRE COUNCIL  
BLAKE GIDDY  
P.O. BOX 3078  
WEST KEMPSEY NSW 2440

BATCHNUMBER: 24/1143  
No. of SAMPLES: 12  
DATE COLLECTED: 08/05/24  
DATE RECEIVED: 08/05/24  
TIME RECEIVED: 16:50  
DATE TESTING COMMENCED:  
08/05/24

### REPORT OF ANALYSIS

SAMPLE REFERENCE	SAMPLE DESCRIPTION
24/1143/1	South Kempsey TP
24/1143/2	Crescent Head CW
24/1143/3	Gladstone TP
24/1143/4	Frederickton TP
24/1143/5	South West Rocks CW
24/1143/6	North St Final TP
24/1143/7	Hat Head C Well
24/1143/8	South Kempsey STP Head Wall Day Pond
24/1143/9	Upstream Gladstone TP
24/1143/10	Downstream Gladstone TP
24/1143/11	Upstream Frederickton TP
24/1143/12	Downstream Frederickton TP

ANALYSIS	UNITS	24/1143/1	24/1143/2	24/1143/3	24/1143/4	METHOD NO
pH	pH unit	6.8	6.8	7.6	7.4	APHA 4500-H+ B
Conductivity	µS/cm	-	673	-	-	APHA 2510 B
Turbidity	NTU	-	1.3	-	-	APHA 2130 B
Transmittance	%	-	-	53.7	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	-	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	-	-	-	-	APHA 2320 B
Total Suspended Solids	mg/L	<2	<2	14	2	APHA 2540 D
Biochem Oxygen Demand (BOD <sub>5</sub> )	mg/L	3	<2	7	6	APHA 5210 B



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	24/1143/1	24/1143/2	24/1143/3	24/1143/4	METHODNO
Nitrate Nitrogen	mg/L	-	9.43	-	-	APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-	-	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	1.43	0.09	0.78	5.48	APHA 4500-NH3 H
Total Nitrogen	mg/L	7.75	10.7	3.28	11.3	APHA 4500-P J
Total Phosphorus	mg/L	2.28	0.05	4.15	3.39	APHA 4500-P J
Oil & Grease	mg/L	<2	<2	<2	<2	EL23A
Chlorophyll-a	µg/L	-	-	45	3	APHA 10200 H
Potassium	mg/L	-	-	-	-	EL9A
Chloride	mg/L	-	-	-	-	EL10
Arsenic	mg/L	-	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	2,050	0	2,400	6,800	ELM 3

ANALYSIS	UNITS	24/1143/5	24/1143/6	24/1143/7	24/1143/8	METHODNO
pH	pH unit	7.0	7.0	7.1	-	APHA 4500-H+ B
Conductivity	µS/cm	504	-	960	-	APHA 2510 B
Turbidity	NTU	1.0	-	1.3	-	APHA 2130 B
Transmittance	%	-	-	-	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	615	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	30	-	55	-	APHA 2320 B
Total Suspended Solids	mg/L	<2	23	<2	-	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	<2	20	<2	-	APHA 5210 B
Nitrate Nitrogen	mg/L	-	5.46	3.56	-	APHA 4500-NO3I
Nitrite Nitrogen	mg/L	-	4.13	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	0.06	0.04	<0.02	-	APHA 4500-NH3 H
Total Nitrogen	mg/L	3.15	12.0	4.75	-	APHA 4500-P J
Total Phosphorus	mg/L	0.27	0.26	0.10	-	APHA 4500-P J
Oil & Grease	mg/L	<2	<2	<2	-	EL23A
Chlorophyll-a	µg/L	-	130	-	-	APHA 10200 H
Potassium	mg/L	12	-	21	-	EL9A
Chloride	mg/L	88	-	140	-	EL10
Arsenic	mg/L	<0.012	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	5	1,050	3	5,050	ELM 3



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	24/1143/9	24/1143/10	24/1143/11	24/1143/12	METHODNO
pH	pH unit	-	-	-	-	APHA 4500-H+ B
Conductivity	µS/cm	-	-	-	-	APHA 2510 B
Turbidity	NTU	-	-	-	-	APHA 2130 B
Transmittance	%	-	-	-	-	APHA 5910
Total Dissolved Solids	mg/L	-	-	-	-	EL7B
Alkalinity	mg CaCO <sub>3</sub> /L	-	-	-	-	APHA 2320 B
Total Suspended Solids	mg/L	-	-	-	-	APHA 2540 D
Biochem Oxygen Demand (BOD5)	mg/L	-	-	-	-	APHA 5210 B
Nitrate Nitrogen	mg/L	-	-	-	-	APHA 4500-NO3 I
Nitrite Nitrogen	mg/L	-	-	-	-	APHA 4500-NO 2
Ammonia Nitrogen	mg/L	-	-	-	-	APHA 4500-NH3 H
Total Nitrogen	mg/L	-	-	-	-	APHA 4500-P J
Total Phosphorus	mg/L	-	-	-	-	APHA 4500-P J
Oil & Grease	mg/L	-	-	-	-	EL23A
Chlorophyll-a	µg/L	-	-	-	-	APHA 10200 H
Potassium	mg/L	-	-	-	-	EL9A
Chloride	mg/L	-	-	-	-	EL10
Arsenic	mg/L	-	-	-	-	EL9A
Thermotolerant Coliforms	cfu/100mL	210	220	75	120	ELM 3

ANALYSIS	UNITS	24/1143/1	24/1143/2	24/1143/3	24/1143/4	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
PFPeA (2706-90-3)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFHxA (307-24-4)	ug/L	0.016	0.018	<0.01	<0.01	NR70
PFHpA (375-85-9)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFOA (335-67-1)	ug/L	<0.01	0.033	<0.01	<0.01	NR70
PFNA (375-95-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDA (335-76-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFUdA (2058-94-8)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDoA (307-55-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFTTrDA (72629-94-8)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFTeDA (376-06-7)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFHxDA (67905-19-5)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70
PFODO (16517-11-6)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
FOUEA (70887-84-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFDS (335-77-3)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFPeS (2706-91-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFHxS (355-46-4)	ug/L	0.012	<0.01	<0.01	<0.01	NR70
PFHpS (375-92-8)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFOS (1763-23-1)	ug/L	0.040	0.036	<0.02	0.046	NR70
PFNS (68259-12-1)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
PFBS (375-73-5)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	24/1143/1	24/1143/2	24/1143/3	24/1143/4	METHODNO
PFOSA (754-91-6)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-MeFOSA (31506-32-8)	ug/L	<0.05	<0.05	<0.02	<0.02	NR70
N-EtFOSA (4151-50-2)	ug/L	<0.05	<0.05	<0.05	<0.02	NR70
N-MeFOSAA (2355-31-9)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-EtFOSAA (2991-50-6)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
N-MeFOSE (24448-09-7)	ug/L	<0.05	<0.05	<0.05	<0.05	NR70
N-EtFOSE (1691-99-2)	ug/L	<0.08	<0.05	<0.05	<0.05	NR70
4:2FTS (757124-72-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
6:2FTS (27619-97-2)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
8:2FTS (39108-34-4)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
10:2FTS (120226-60-0)	ug/L	<0.01	<0.01	<0.01	<0.01	NR70
8:2diPAP (678-41-1)	ug/L	<0.02	<0.02	<0.02	<0.02	NR70



Accredited for compliance with ISO/IEC 17025 - Testing

Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	24/1143/5	24/1143/6	24/1143/7	24/1143/8	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	<0.05	<0.05	<0.05	-	NR70
PFPeA (2706-90-3)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFHxA (307-24-4)	ug/L	0.012	<0.01	<0.01	-	NR70
PFHpA (375-85-9)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOA (335-67-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFNA (375-95-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDA (335-76-2)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFUdA (2058-94-8)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDoA (307-55-1)	ug/L	<0.02	<0.01	<0.01	-	NR70
PFTriDA (72629-94-8)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFTeDA (376-06-7)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFHxDA (67905-19-5)	ug/L	<0.02	<0.02	<0.02	-	NR70
PFODO (16517-11-6)	ug/L	<0.05	<0.05	<0.05	-	NR70
FOUEA (70887-84-2)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFDS (335-77-3)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFPeS (2706-91-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFHxS (355-46-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFHpS (375-92-8)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOS (1763-23-1)	ug/L	<0.02	0.026	<0.02	-	NR70
PFNS (68259-12-1)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFBS (375-73-5)	ug/L	<0.01	<0.01	<0.01	-	NR70
PFOSA (754-91-6)	ug/L	<0.01	<0.01	<0.01	-	NR70
N-MeFOSA (31506-32-8)	ug/L	<0.05	<0.02	<0.02	-	NR70
N-EtFOSA (4151-50-2)	ug/L	<0.05	<0.02	<0.02	-	NR70
N-MeFOSAA (2355-31-9)	ug/L	<0.01	<0.01	<0.01	-	NR70
N-EtFOSAA (2991-50-6)	ug/L	<0.02	<0.01	<0.01	-	NR70
N-MeFOSE (24448-09-7)	ug/L	<0.05	<0.05	<0.05	-	NR70
N-EtFOSE (1691-99-2)	ug/L	<0.08	<0.05	<0.05	-	NR70
4:2FTS (757124-72-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
6:2FTS (27619-97-2)	ug/L	<0.01	<0.01	<0.01	-	NR70
8:2FTS (39108-34-4)	ug/L	<0.01	<0.01	<0.01	-	NR70
10:2FTS (120226-60-0)	ug/L	<0.01	<0.01	<0.01	-	NR70
8:2 diPAP (678-41-1)	ug/L	<0.02	<0.02	<0.02	-	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

ANALYSIS	UNITS	24/1143/9	24/1143/10	24/1143/11	24/1143/12	METHODNO
<b>PFAS*</b>						
PFBA (375-22-4)	ug/L	-	-	-	-	NR70
PFPeA (2706-90-3)	ug/L	-	-	-	-	NR70
PFHxA (307-24-4)	ug/L	-	-	-	-	NR70
PFHpA (375-85-9)	ug/L	-	-	-	-	NR70
PFOA (335-67-1)	ug/L	-	-	-	-	NR70
PFNA (375-95-1)	ug/L	-	-	-	-	NR70
PFDA (335-76-2)	ug/L	-	-	-	-	NR70
PFUdA (2058-94-8)	ug/L	-	-	-	-	NR70
PFDaA (307-55-1)	ug/L	-	-	-	-	NR70
PFTTrDA (72629-94-8)	ug/L	-	-	-	-	NR70
PFTeDA (376-06-7)	ug/L	-	-	-	-	NR70
PFHxDA (67905-19-5)	ug/L	-	-	-	-	NR70
PFODO (16517-11-6)	ug/L	-	-	-	-	NR70
FOUEA (70887-84-2)	ug/L	-	-	-	-	NR70
PFDS (335-77-3)	ug/L	-	-	-	-	NR70
PFPeS (2706-91-4)	ug/L	-	-	-	-	NR70
PFHxS (355-46-4)	ug/L	-	-	-	-	NR70
PFHpS (375-92-8)	ug/L	-	-	-	-	NR70
PFOS (1763-23-1)	ug/L	-	-	-	-	NR70
PFNS (68259-12-1)	ug/L	-	-	-	-	NR70
PFBS (375-73-5)	ug/L	-	-	-	-	NR70
PFOSA (754-91-6)	ug/L	-	-	-	-	NR70
N-MeFOSA (31506-32-8)	ug/L	-	-	-	-	NR70
N-EtFOSA (4151-50-2)	ug/L	-	-	-	-	NR70
N-MeFOSAA (2355-31-9)	ug/L	-	-	-	-	NR70
N-EtFOSAA (2991-50-6)	ug/L	-	-	-	-	NR70
N-MeFOSE (24448-09-7)	ug/L	-	-	-	-	NR70
N-EtFOSE (1691-99-2)	ug/L	-	-	-	-	NR70
4:2FTS (757124-72-4)	ug/L	-	-	-	-	NR70
6:2FTS (27619-97-2)	ug/L	-	-	-	-	NR70
8:2FTS (39108-34-4)	ug/L	-	-	-	-	NR70
10:2FTS (120226-60-0)	ug/L	-	-	-	-	NR70
8:2 diPAP (678-41-1)	ug/L	-	-	-	-	NR70



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.

**Comments**

Sample(s) collected by client and analysed as received in accordance with "Standard Methods for the Examination of Water & Wastewater", 24th Edition, 2022, APHA. Raw data sheets stating analysis dates are available upon request.

Tests marked with '#' are not covered by NATA Accreditation.

Note: Microbiological results are presumptive.

Measurement Uncertainty is available upon request.

\*Analysis conducted by a subcontracted laboratory (NATA Accreditation Number 198) RN 1428891.

Report Date: 22/05/24



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Number: 12359

Approved:

A handwritten signature in black ink that reads "Shane Ewart".

Shane Ewart  
Technical Supervisor  
Microbiology and Chemistry

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian and International standards.